

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 615

Dated:

It is certified that an inspection team headed by **Mr. Anuj Kumar, Lab Chemist** (Name of Officers with designation) from **Uttar Pradesh Jal Nigam (Rural), Pilibhit PHED** inspected the **Bhasins International School, Sirsa Road, Bhasins Acres, Puranpur, Pilibhit, Uttar Pradesh** (Name & Address of the school) on **18/05/2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **PIL/26/05/615** dated **19.05.2026** Of **Uttar Pradesh Jal Nigam (Rural), Pilibhit (PHED Lab)** certified that the **Bhasins International School, Sirsa Road, Bhasins Acres, Puranpur, Pilibhit, Uttar Pradesh** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 18-11-2026

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

U P Jal Nigam (Gramin)
Pilibhit

To

MANAGER

Bhasins International School, Sirsa
Road, Bhasins Acres, Puranpur,
Pilibhit, Uttar Pradesh

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Testing Laboratory (Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,
U.P. Jal Nigam In front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001

WATER ANALYSIS REPORT

Rept. No	615	Date:	19.05.2026
Customer Details			
Office Name and Address	Bhasins International School, Sirsa Road, Bhasins Acres, Puranpur, Pilibhit.		
Ref Letter No & Date	Application by customer letter no.- BIS/77/2026 Date 18.05.2026		
Sample Description			
District	Pilibhit	Block	Puranpur
Gram Panchayat/Nagar Panchayat	Narayanpur	Village/Ward No.	Narayanpur
Habitation	Sirsa Road, Bhasin Acres	Location	Bhasins International School
Water Source	Submersible Pump	Sample Code	PIL/26/05/615
Date & Time of Sample Collection	18.05.2026 10:00AM	Sample Collector Name	Mr. Akshat Bhasin
Receiving Date & Time	18.05.2026 12:32PM	Sample Receiver	Mr. Sanjeev kumar
Water Sample Type	Drinking Water	Quantity of Sample	1000ml
Environmental Condition			
Temperature	25°C ±3°C	Humidity	50% ±15%
Analysis Date	19.05.2026		

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Chloride	12.99	mg/l	250	1000	IS 3025 (Part 32) : 2019
2	Fluoride	0.112	mg/l	1	1.5	APHA 24th Edition 4500-F ⁻ Method C (Electrode Method) : 2023
3	Iron	0.126	mg/l	1	No relaxation	IS 3025 (Part 53) : 2019
4	Nitrate	2.018	mg/l	45	No relaxation	APHA 24th Edition 4500-NO ₃ ⁻ Method B (UV Screening Method):2023
5	pH	7.83	NA	6.5-8.5	No relaxation	IS 3025 (Part 11) : 2022
6	Sulphate	3.007	mg/l	200	400	APHA 24th Edition 4500-SO ₄ ⁻² Method E (Turbidimetric Method) : 2023
7	TDS	225	mg/l	500	2000	IS 3025 (Part 16) : 2023
8	Total Alkalinity	170	mg/l	200	600	IS 3025 (Part 23) : 2023
9	Total Hardness	104	mg/l	200	600	IS 3025 (Part 21) : 2019
10	Turbidity	0.85	NTU	1	5	IS 3025 (Part 10) : 2023
11	Taste	Agreeable	NA	Agreeable	Agreeable	IS 3025(Part 8) : 2023
12	Odour	Agreeable	NA	Agreeable	Agreeable	IS 3025(Part 5) : 2018

- Note. 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 2-3 days (in case of non perishable items only) from the date of issue of tests reports unless.
5. BDL- Below Detection Limit, OHT-Over Head Tank, PWS- Pipe Water Supply.

Sanjeev
Analysis by
Sanjeev Kumar
(Lab Assistant)

Antj Kumar
Authorized Signatory
Antj Kumar
(Chemist)
U.P. Jal Nigam
PILIBHIT

End of the Report



District Level Water Testing Laboratory (Uttar Pradesh Jal Nigam, Pilibhit)

Address: Office of Executive Engineer, Construction Division,
U.P Jal Nigam In front of district veterinary Hospital, Tanakpur road, Pilibhit. Pin- 262001

WATER ANALYSIS REPORT

Rept. No	615	Date:	19.05.2026
----------	-----	-------	------------

Customer Details

Office Name and Address	Bhasins International School, Sirsa Road, Bhasins Acres, Puranpur, Pilibhit.
Ref Letter No & Date	Application by customer letter no.- BIS/77/2026 Date 18.05.2026

Sample Description

District	Pilibhit	Block	Puranpur
Gram Panchayat/Nagar Panchayat	Narayanpur	Village/Ward No.	Narayanpur
Habitation	Sirsa Road Bhasin Acres	Location	Bhasins International School
Water Source	Submersible Pump	Sample Code	PIL/26/05/615
Date & Time of Sample Collection	18.05.2026 10:00AM	Sample Collector Name	Mr. Akshat Bhasin
Receiving Date & Time	18.05.2026 12:32PM	Sample Receiver	Mr. Sanjeev kumar
Water Sample Type	Drinking Water	Quantity of Sample	1000ml

Environmental Condition

Temperature	25°C ±3°C	Humidity	50% ±15%
Analysis Date	19.05.2026		

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	Total Coliform	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)
2	E .Coli	00	CFU	00	No relaxation	APHA 23 rd Edition :2017 (IS 10500)

- Note 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 48 hrs (in case of non perishable items only) from the date of issue of tests reports unless.
5. OHT-Over Head Tank, PWS- Pipe Water Supply.


Analysis by
Sarvesh Kumar
(Microbiologist)

End of the Report